



Utah Department of  
**Health & Human Services**  
Licensing & Background Checks

### Child Care Licensing - FIRE Inspection Checklist

[Childcarelicensing.utah.gov](http://Childcarelicensing.utah.gov)

This inspection checklist is the tool CCL  
licensors use to ensure consistency for every  
inspection. **(Updated 11/2023)**

Facility Name:		Facility ID:		Phone Number:	
Email Address:				Owner / Provider / Director:	

**General Notes:**

- *I will email you this inspection checklist after the inspection is completed.* I will send you an official inspection report once this inspection has been approved by CCL management.

- *You may submit feedback on this inspection* through your Child Care Licensing Portal or at: <https://childcarelicensing.utah.gov/contact-us/give-ccl-your-feedback/>

#### Signature Information

Inspection Type:		Date:		Time Started:		Time Ended:	
Number of Rule Noncompliances:		Name of Individual Informed of this Inspection:					
Licensors Conducting this Inspection:				CCL Observer:			

The licensor reviewed all compliance with me for this inspection

Please sign or type your name and the date:

Rule #	Rule Description	C	NC	NA	Compliance Required By:	Corrected During Inspection	Notes
	C = Compliant NC = Not Compliant NA = Not Assessed at this inspection						
Section 4: License Application, Renewal, Changes and Variances							
4(3)(a)-(h)	<p>If the local fire authority states in writing that an applicant for a new license or a renewal does not require a fire inspection, the department shall verify the applicant's compliance with the following:</p> <ul style="list-style-type: none"> <li>- address numbers and letters are readable from the street;</li> <li>- exit doors operate properly and are well maintained;</li> <li>- there are no obstructions in exits, aisles, corridors, and stairways;</li> <li>- <b>(Centers Only)</b> exit doors are unlocked from the inside during business hours;</li> <li>- <b>(Centers Only)</b> exits are clearly identified;</li> <li>- there is at least one unobstructed fire extinguisher on each level of the building, currently charged and serviced, and mounted not more than five feet above the floor;</li> <li>- there are working smoke detectors that are properly installed on each level of the building; and</li> <li>- boiler, mechanical, and electrical panel rooms are not used for storage.</li> </ul>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		<input type="checkbox"/>	